

Pleasants County Board of Education
Belmont Elementary School
(Name of School)

Notice to: Employees, PTA and Parents

In accordance with EPA regulations this facility has been inspected for friable (easily crumbled) and non-friable building materials which contain asbestos. Airborne asbestos fibers may cause health problems.

Friable asbestos-containing material is present in the following building materials:

None

Non-friable asbestos-containing material is present in the following building materials: *Floor tile and fire doors.*

Immediate measures taken to prevent potentially harmful exposure to these materials are as follows: *The floor tile and doors involved were thoroughly inspected and found to be in good condition. The floor tile had an adequate layer of wax as added protection. They should not present a danger unless substantially disturbed or damaged.*

Long-term plans being developed to permanently control asbestos-containing materials in this building include the following options: *Maintenance and custodial personnel have been and will continue to be properly trained. An inspection and surveillance program has been implemented to insure the integrity and safety of the floors and doors involved.*

EPA regulations require staff and parents to be notified when friable or non-friable asbestos is found in a school building. You can be assured that all necessary actions will be taken to protect the health and safety of the students and staff.

A record of the inspection, a diagram of the location(s) of friable asbestos-containing materials, the schools asbestos management plan and a copy of relevant EPA regulations are available in the office, at the Board Office (2272 N. Pleasants Highway), or at the Maintenance Department (1009 Maple Street).

An asbestos awareness seminar is given from time to time by the Pleasants County Board of Education. The residents of Pleasants County are welcome to attend. For further information contact Rex Cox at 684-3047.

SIGNED: _____

Rex Allen Cox

Date: August 23, 2010

Pleasants County Board of Education

St. Marys Elementary School

(Name of School)

Notice to: Employees, PTO and Parents

In accordance with EPA regulations this facility has been inspected for friable (easily crumbled) and non-friable building materials which contain asbestos. Airborne asbestos fibers may cause health problems.

Friable asbestos-containing material is present in the following building materials:

None

Non-friable asbestos-containing material is present in the following building materials: *Certain floor tile and fire doors.*

Immediate measures taken to prevent potentially harmful exposure to these materials are as follows: *The floor tile and doors involved were thoroughly inspected and found to be in good condition. The floor tile have been covered with new tile. They should not present a danger unless substantially disturbed or damaged.*

Long-term plans being developed to permanently control asbestos-containing materials in this building include the following options: *Maintenance and custodial personnel have been and will continue to be properly trained. An inspection and surveillance program has been implemented to insure the integrity and safety of the floors and doors involved.*

EPA regulations require staff and parents to be notified when friable or non-friable asbestos is found in a school building. You can be assured that all necessary actions will be taken to protect the health and safety of the students and staff.

A record of the inspection, a diagram of the location(s) of friable asbestos-containing materials, the schools asbestos management plan and a copy of relevant EPA regulations are available in the office, at the Board Office (2272 N. Pleasants Highway), or at the Maintenance Department (1009 Maple Street).

An asbestos awareness seminar is given from time to time by the Pleasants County Board of Education. The residents of Pleasants County are welcome to attend. For further information contact Rex Cox at 684-3047.

SIGNED: *Rex Allen Cox*

Date: August 23, 2010

Pleasants County Board of Education
Pleasants County Middle School
(Name of School)

Notice to: Employees, PTO and Parents

In accordance with EPA regulations this facility has been inspected for friable (easily crumbled) and non-friable building materials which contain asbestos. Airborne asbestos fibers may cause health problems.

Friable asbestos-containing material is present in the following building materials:

None

Non-friable asbestos-containing material is present in the following building materials: *Floor tile and fire doors.*

Immediate measures taken to prevent potentially harmful exposure to these materials are as follows: *The floor tile and doors involved were thoroughly inspected and found to be in good condition. The floor tile had an adequate layer of wax as added protection. They should not present a danger unless substantially disturbed or damaged.*

Long-term plans being developed to permanently control asbestos-containing materials in this building include the following options: *Maintenance and custodial personnel have been and will continue to be properly trained. An inspection and surveillance program has been implemented to insure the integrity and safety of the floors and doors involved.*

EPA regulations require staff and parents to be notified when friable or non-friable asbestos is found in a school building. You can be assured that all necessary actions will be taken to protect the health and safety of the students and staff.

A record of the inspection, a diagram of the location(s) of friable asbestos-containing materials, the schools asbestos management plan and a copy of relevant EPA regulations are available in the office, at the Board Office (227 N. Pleasants Highway), or at the Maintenance Department (1009 Maple Street).

An asbestos awareness seminar is given from time to time by the Pleasants County Board of Education. The residents of Pleasants County are welcome to attend. For further information contact Rex Cox at 684-3047.

SIGNED: *Rex Allen Cox*

Date: August 23, 2010

Pleasants County Board of Education

St. Marys High School

(Name of School)

Notice to: Employees, Advisory Committee and Parents

In accordance with EPA regulations this facility has been inspected for friable (easily crumbled) and non-friable building materials which contain asbestos. Airborne asbestos fibers may cause health problems.

Friable asbestos-containing material is present in the following building materials:

None

Non-friable asbestos-containing material is present in the following building materials: *Floor tile and fire doors.*

Immediate measures taken to prevent potentially harmful exposure to these materials are as follows: *The floor tile and doors involved were thoroughly inspected and found to be in good condition. The floor tile had an adequate layer of wax as added protection. They should not present a danger unless substantially disturbed or damaged.*

Long-term plans being developed to permanently control asbestos-containing materials in this building include the following options: *Maintenance and custodial personnel have been and will continue to be properly trained. An inspection and surveillance program has been implemented to insure the integrity and safety of the floors and doors involved.*

EPA regulations require staff and parents to be notified when friable or non-friable asbestos is found in a school building. You can be assured that all necessary actions will be taken to protect the health and safety of the students and staff.

A record of the inspection, a diagram of the location(s) of friable asbestos-containing materials, the schools asbestos management plan and a copy of relevant EPA regulations are available in the office, at the Board Office (2272 N. Pleasants Highway), or at the Maintenance Department (1009 Maple Street).

An asbestos awareness seminar is given from time to time by the Pleasants County Board of Education. The residents of Pleasants County are welcome to attend. For further information contact Rex Cox at 684-3047.

SIGNED: _____

Rex Allen Cox

Date: August 23, 2010

Pleasants County Board of Education
Mid-Ohio Valley Technical Center
(Name of School)

Notice to: Employees, LSIC and Parents

In accordance with EPA regulations this facility has been inspected for friable (easily crumbled) and non-friable building materials which contain asbestos. Airborne asbestos fibers may cause health problems.

Friable asbestos-containing material is present in the following building materials:

None

Non-friable asbestos-containing material is present in the following building materials: *Floor tile and fire doors.*

Immediate measures taken to prevent potentially harmful exposure to these materials are as follows: *The floor tile and doors involved were thoroughly inspected and found to be in good condition. The floor tile had an adequate layer of wax as added protection. They should not present a danger unless substantially disturbed or damaged.*

Long-term plans being developed to permanently control asbestos-containing materials in this building include the following options: *Maintenance and custodial personnel have been and will continue to be properly trained. An inspection and surveillance program has been implemented to insure the integrity and safety of the floors and doors involved.*

EPA regulations require staff and parents to be notified when friable or non-friable asbestos is found in a school building. You can be assured that all necessary actions will be taken to protect the health and safety of the students and staff.

A record of the inspection, a diagram of the location(s) of friable asbestos-containing materials, the schools asbestos management plan and a copy of relevant EPA regulations are available in the office, at the Board Office (2272 N. Pleasants Highway), or at the Maintenance Department (1009 Maple Street).

An asbestos awareness seminar is given from time to time by the Pleasants County Board of Education. The residents of Pleasants County are welcome to attend. For further information contact Rex Cox at 684-3047.

SIGNED: *Rex Allen Cox*

Date: August 23, 2010

Pleasants County Board of Education
Board Office
(Name of School)
Notice to: Employees

In accordance with EPA regulations this facility has been inspected for friable (easily crumbled) and non-friable building materials which contain asbestos. Airborne asbestos fibers may cause health problems.

Friable asbestos-containing material is present in the following building materials:

None

Non-friable asbestos-containing material is present in the following building materials: *Floor tile.*

Immediate measures taken to prevent potentially harmful exposure to these materials are as follows: *The floors and doors involved were thoroughly inspected and found to be in good condition. The floor tile had an adequate layer of wax as added protection. They should not present a danger unless substantially disturbed or damaged.*

Long-term plans being developed to permanently control asbestos-containing materials in this building include the following options: *Maintenance and custodial personnel have been and will continue to be properly trained. An inspection and surveillance program has been implemented to insure the integrity and safety of the floors and doors involved.*

EPA regulations require staff and parents to be notified when friable or non-friable asbestos is found in a school building. You can be assured that all necessary actions will be taken to protect the health and safety of the students and staff.

A record of the inspection, a diagram of the location(s) of friable asbestos-containing materials, the schools asbestos management plan and a copy of relevant EPA regulations are available in the office, at the Board Office (2272 N. Pleasants Highway), or at the Maintenance Department (1009 Maple Street).

An asbestos awareness seminar is given from time to time by the Pleasants County Board of Education. The residents of Pleasants County are welcome to attend. For further information contact Rex Cox at 684-3047.

SIGNED: _____

Date: August 23, 2010

Pleasants County Board of Education
School Service/Maintenance Department

(Name of School)

Notice to: Employees

In accordance with EPA regulations this facility has been inspected for friable (easily crumbled) and non-friable building materials which contain asbestos. Airborne asbestos fibers may cause health problems.

Friable asbestos-containing material is present in the following building materials:

None

Non-friable asbestos-containing material is present in the following building materials: *Floor tile and fire doors.*

Immediate measures taken to prevent potentially harmful exposure to these materials are as follows: *The floor tile and doors involved were thoroughly inspected and found to be in good condition. The floor tile had an adequate layer of wax as added protection. They should not present a danger unless substantially disturbed or damaged.*

Long-term plans being developed to permanently control asbestos-containing materials in this building include the following options: *Maintenance and custodial personnel have been and will continue to be properly trained. An inspection and surveillance program has been implemented to insure the integrity and safety of the floors and doors involved.*

EPA regulations require staff and parents to be notified when friable or non-friable asbestos is found in a school building. You can be assured that all necessary actions will be taken to protect the health and safety of the students and staff.

A record of the inspection, a diagram of the location(s) of friable asbestos-containing materials, the schools asbestos management plan and a copy of relevant EPA regulations are available in the office, at the Board Office (2272 N. Pleasants Highway), or at the Maintenance Department (1009 Maple Street).

An asbestos awareness seminar is given from time to time by the Pleasants County Board of Education. The residents of Pleasants County are welcome to attend. For further information contact Rex Cox at 684-3047.

SIGNED: *Rex Allen Cox*

Date: August 23, 2010

Pleasants County Board of Education
School Bus Garage
(Name of School)
Notice to: Employees

In accordance with EPA regulations this facility has been inspected for friable (easily crumbled) and non-friable building materials which contain asbestos. Airborne asbestos fibers may cause health problems.

Friable asbestos-containing material is present in the following building materials:
None

Non-friable asbestos-containing material is present in the following building materials: *Floor tile and fire doors.*

Immediate measures taken to prevent potentially harmful exposure to these materials are as follows: *The floor tile and doors involved were thoroughly inspected and found to be in good condition. The floor tile had an adequate layer of wax as added protection. They should not present a danger unless substantially disturbed or damaged.*

Long-term plans being developed to permanently control asbestos-containing materials in this building include the following options: *Maintenance and custodial personnel have been and will continue to be properly trained. An inspection and surveillance program has been implemented to insure the integrity and safety of the floors and doors involved.*

EPA regulations require staff and parents to be notified when friable or non-friable asbestos is found in a school building. You can be assured that all necessary actions will be taken to protect the health and safety of the students and staff.

A record of the inspection, a diagram of the location(s) of friable asbestos-containing materials, the schools asbestos management plan and a copy of relevant EPA regulations are available in the office, at the Board Office (2272 N. Pleasants Highway), or at the Maintenance Department (1009 Maple Street).

An asbestos awareness seminar is given from time to time by the Pleasants County Board of Education. The residents of Pleasants County are welcome to attend. For further information contact Rex Cox at 684-3047.

SIGNED: *Rex Allen Cox*

Date: August 23, 2010